



# UN38.3 试验概要

## UN38.3 Test Summary



812300500040031

单位信息 Company information			
委托单位 Consignor	上海派智能源股份有限公司 Shanghai PYTES Energy Co., Ltd. 上海市奉贤区青村镇光明金钱公路 3492 号第 9 幢 Building 9, No.3492 Jinqian Road, Fengxian District, Shanghai, China 021-57475830 wanwan_tan@dlgbattery.cn www.pytesgroup.com		
生产单位 Manufacturer	上海派智能源股份有限公司 Shanghai PYTES Energy Co., Ltd. 上海市奉贤区青村镇光明金钱公路 3492 号第 9 幢 Building 9, No.3492 Jinqian Road, Fengxian District, Shanghai, China 021-57475830 wanwan_tan@dlgbattery.cn www.pytesgroup.com		
测试单位 Test lab	上海化工院检测有限公司 Shanghai Institute of Chemical Industry Testing Co., Ltd. 中国.上海.普陀区云岭东路 345 号, 200062 No.345 East Yunling Road, Putuo, Shanghai, China 200062 86-21-31765555 battery@ghs.cn www.ghs.cn		
电池信息 Battery information			
名称 Name	锂离子电池组 Lithium ion Battery Pack	品牌 Brand	/
型号 Type	HV48100 BMU	原始测试型号 Original tested type	/
标称电压(V) Nominal voltage	51.2	容量/能量 Capacity/energy	100Ah 5.12kWh
描述 Description	可充电锂离子电池组 Rechargeable Li-ion battery	锂含量(g) Li content	/
质量(kg) Mass	43.9	外观 Appearance	银色金属外壳 Silvery metal shell
测试信息 Test information			
原报告编号 Original test report No.	1123050081a	测试报告日期 Date of test report	2023-07-03
测试标准 Test standard	联合国《试验和标准手册》第 38.3 章 UNITED NATIONS Manual of Tests and Criteria 38.3 ST/SG/AC.10/11/Rev.7&Am end.1		
T.1 高度模拟 Altitude simulation	合格 Passed	T.2 温度测试 Thermal test	合格 Passed
T.3 振动测试 Vibration	合格 Passed	T.4 冲击测试 Shock	合格 Passed
T.5 外部短路 External short circuit	合格 Passed	T.6 挤压 Crush	合格 Passed
T.7 过度充电 Overcharge	/	T.8 强制放电 Forced discharge	合格 Passed
38.3.3 (f)	/	38.3.3 (g)	/






# UN38.3 试验概要

## UN38.3 Test Summary






812300500040031


### 样品图片 Sample Picture



## Pytes

Battery Model	10V40100 BMU
Battery Cell type	LFP Battery
Operating Voltage Range	47.5V-57.6V
Nominal Voltage	51.2V
Rated Energy	5.12kWh
Rated Capacity	100Ah
Rated Charge/Discharge Current	50A
Maximum Charge/Discharge Current	50A
Protective Class	Class I
Ingress Protection Code	IP20



<p>结论 Conclusion</p>	<p>测试样品符合联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7&amp;Amend.138.3 标准要求。The tested samples meet the requirements of test items of the UNITED NATIONS Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7&amp;Amend.138.3</p>		
<p>备注 Remark</p>	<p>该模组未安装过充电保护装置,按设计要求只用于作为另一带过充电保护装置电池组或设备的部件,未进行过充电测试。 Modules not equipped with battery overcharge protection that are designed for use only as a component in another battery or in equipment, which affords such protection, are not subject to the requirements of this test.</p>		
<p>签名 Signature 职务 Title</p>	<p> 王寅 副总工程师 Vice chief engineer</p>	<p>签发日期 Issued date</p>	<p>2023-07-10</p>

-验证码:212287-

\*\*\*报告结束\*\*\*